

Village of Lockland
Application for Residential Sidewalk or Driveway Apron Replacement

Location of proposed work:

Address: _____

Owner's Name: _____

Owner's Phone #: _____

Contractor's Name: _____

Contractor's Address: _____

Contractor's Phone #: _____

Describe extent of replacement (number of squares, etc. to be replaced):

Specifications for Sidewalk Replacement

Dimensions

Sidewalks shall be 5" thick and as wide as those being replaced, but under no circumstances less than 30" wide.

Driveway aprons shall be 7" thick, or 6" thick if 21-pound wire mesh reinforcement is used, and shall be the equivalent area of that being replaced.

Type of Material

Concrete for both the sidewalk and the driveway apron shall be 4,000 PSI (or Class "C") concrete.

Finish on Concrete Work

Concrete shall be poured in level forms, raked off, and floated down twice using a wood float, with an appropriate curing time between float applications. Final finish shall be a no-skid surface, edges of work shall be tooled with an edger and the sidewalk surface shall be jointed into squares with a jointing tool.
NO BROOM FINISH!

Drying Recommendations

No for traffic for three (3) days. No automobile traffic for four (4) days.

Call (513) 733-0957 to schedule the required inspection of forms before pouring concrete.